



Leah Cameron <cameronl@grafton-ma.gov>

Request for Comments: 244 Worcester Street

Michael Killeen <killeenm@grafton-ma.gov>
To: Leah Cameron <cameronl@grafton-ma.gov>

Tue, Sep 7, 2021 at 8:17 AM

Good morning,

The Fire Department simply seeks the reinforce the following minimum requirements

Roadways / Driveways / Parking Lots

- Entrance shall be void of all obstacles to a minimum of 30 feet (i.e. light poles, trees, shrubs, stone walls, gates and posts, mailboxes, etc.)
- Should be at least 24 feet wide, preferably 28 feet wide
- Parking lots shall have turning radii that will accommodate fire apparatus

Thank you.

Respectfully,

Captain Michael Killeen
Fire Prevention Officer
Grafton Fire Department

[Quoted text hidden]